

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 222/223 Dated: 25/03/2026
It is certified that an inspection team headed by Sh. Parmindar SDE No-2 Bhiwani
(Name of Officers with designation) from PHESD No-2 Bhiwani PHED
inspected the Adarsh Sr. Sec. School Tasham Gurgaon Nagar
(Name & Address of the school) on 25/03/2026 (date of inspection) and on the basis of
Water Test Report (Attached) bearing no. 222/223 dated 27/03/2026
of PHED Lab Bhiwani (PHED Lab) certified that
the Adarsh Sr. Sec. School Tasham (Name of school) has safe drinking water
facilities for the students and members of staff of the institution. School is also maintains the
hygienic sanitation condition in the school building & the campus as per norms prescribed by the
Central/ State/ U.T. Govt.
This certificate is valid till 6 Months

Signature with Seal: [Signature]
Name : Kapil Dev
Designation : E.E.
Name & Address of the Office / Department : PHED

To
Adarsh Sr. Sec. School
Tasham
(Name & Address of the Institution)

EXECUTIVE ENGINEER
PUBLIC HEALTH ENGINEERING DIVIN. NO.2
BHIWANI

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Memo No:- 222

Date:- 27/03/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	BHW/05765/3/2026 / Private	Sample Details	Date & Time
Sender :	Adarsh Sr. Sec. School, Tosham	Collected By	Sh. Bharat Kum...
Location :	, From Adarsh Sr. Sec. School Tosham, Gulshan Naga	Collection Date	20/03/2026 at 09:43
Sample Description :	Drinking Water	Received at lab	27/03/2026 at 11:57
Latitude / Longitude :	75.917323 / 28.880636	Analysis Start Date	27/03/2026
		Analysis End Date	27/03/2026
		Sample Quantity	2 ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	1.02	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2160C
3	Odour	Agreeable	Agreeable	Agreeable	APHA 24th Edition -2150B
4	Color	5	5 Hazen Units	15 Hazen Units	APHA 24th Edition -2120B
5	Total Dissolved Solids @ 180°C ± 2°C	372	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	160	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	24.05	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	24.3	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	120	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	70.9	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	42	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E
12	Fluoride as F	0.26	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron as Fe	0.08	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as No3	0.39	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°C	7.11	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED BHIWANI Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

 **RAJEEV KUMAR ,CHEMIST**
DISTRICT WATER TESTING LABORATORYBHIWANI
email:-chemist.bhiwani@phedharyana.gov.in

Subject : Bacteriological Examination Report of Water Samples

Circle **Bhiwani Circle**

Division **Tosham PHED**

Sub Division **Tosham PHESD**

S.No.	Tested Parameter *	Result (MPN) **	Protocol Used	Potable / Not Potable
Memo No :- 223, Date :- 27/03/2026				
1	Sample ID:-BHW/05764/3/2026 /Sender : Adarsh Sr. Sec. School, Tosham ,Location : , From Adarsh Sr. Sec. School, Tosham Gulshan Naga, Analysis Start/End Date: 25/03/2026 / 27/03/2026, GPS Coordinates: 75.917160 /28.880593			
	Total Coliform per 100 ml	00	IS 15185:2016/APHA 9223B-2023/APHA 9221C-2023	Potable
Abstract Report of Bacteriological Examination Report of Water Sample				
Total Sample		Potable		Not Potable
1		1		0

* Requirement (Acceptable Limit) : Shall not be detectable in any 100 ml sample

** MPN (Most Probable Number) Per 100 ML.

Remarks :-

- * The Results Given above are related to the sample as received and tested in BHIWANI lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.

Sample analyzed by :

RAJEEV KUMAR, CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, BHIWANI
email:-chemist.bhiwani@phedharyana.gov.in